

CERTIFICATE OF COMPLIANCE

Certificate Number 20130724-E211775
Report Reference E211775-20000829
Issue Date 2013-JULY-24

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR UNIVERSITY PARK IL 60484

**This is to certify that
representative samples of**

SIGNALING APPLIANCES AND EQUIPMENT FOR THE
HEARING IMPAIRED FOR USE IN HAZARDOUS
LOCATIONS

Model 224XSTHI, Signal Appliance for the Hearing
Impaired (15 candela) for use in Hazardous Locations,
Class I, Div. 2; Class II, Div 2; and Class III for indoor use
on a wall or ceiling in a non-sleeping area. Indoor use only,
Type 4X, IP66 enclosure.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA 12.12.01 - Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

